

Good Afternoon,

As you are aware we have been carrying out several investigations into the cause of the smell across Callier House,

Following the drainage survey, it has become apparent there is an error with the drainage run. It has been identified there is a soil vent pipe that should be running into a foul drain is incorrectly connected to the storm drain.

**The corrective works are scheduled for this week Thursday 27<sup>th</sup> May between 11am – 1pm.**

Rydon have requested the residents serving the soil vent pipe **do not use their facilities for 2 hours between 11am and 1pm,** as I am sure you can appreciate this is necessary for the works to be undertaken.

I have provided a list below of the postal address's that will be affected, I will also call through the list below to confirm you are in receipt.

First floor  
Flats 10, 11, 12

Second floor  
Flats 20, 22, 23, 24, 25, 26

Third floor  
Flats 34, 36, 37, 39, 39, 40

Fourth Floor  
Flats 48, 50, 51, 52, 53, 54

Fifth Floor  
Flats  
62, 64, 65, 66, 67, 68

Sixth Floor  
Flats 74, 75, 76

Thank you for your cooperation and patience,

Kind Regards

**Daniel Briggs**  
Senior Aftercare Officer



020 8832 3496 | 07966 427203  
[www.chg.org.uk](http://www.chg.org.uk)

Catalyst Housing Ltd, Ealing Gateway,  
[26-30 Uxbridge Road, London W5 2AU](#)

